



Attachment

Relevant Information

EPM reports to the public opinion:

1. As the company had published, last February 15 a technical issue occurred causing a fire in the access tunnel to the machinery room in Guatapé's hydroelectric power plant, located in the East of Antioquia. The cables used for purging power in the plant, from the machinery room to the substation, were partially destroyed.
2. All the equipment of the machinery room in Guatapé's hydroelectric power plant is in excellent conditions, including: turbines, generators, and transformers.
3. In accordance with the failure causes analysis, the hypotheses that the incident has been due to an attack or a malicious act are dismissed.
4. Guatapé hydroelectric power plant, and particularly the affected cables, has always had a preventative and predictive maintenance plan, permanently and firmly observed.
5. EPM is working in coordination with the Ministry of Mining and Energy, the National Operation Council (Consejo Nacional de Operación, CNO) from the electric sector, and XM on this situation in the National Interconnected System.
6. The company reaffirms that they are doing every effort to normalize the plant operation as soon as possible.

Medellin, February 23th of 2016